



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0J1423

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Belleville

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 10/16/2020
 Reported: 11/04/2020

Analytical Testing Parameters

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-01		Collection Date: 10/14/2020 6:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1605	LLW

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-02		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1610	LLW

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-03		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0089	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1612	LLW

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-04		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1614	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-05		Collection Date: 10/14/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.133	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1616	LLW

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-06		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1617	LLW

Client Sample ID: 8	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-07		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1623	LLW

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-08		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0043	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1625	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 10	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-09		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1627	LLW

Client Sample ID: 9	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-10		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0060	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1628	LLW

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-11		Collection Date: 10/14/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0204	0.015 AL	0.0204	mg/L	D	10/28/20 1253	10/30/20 1347	LLW

Client Sample ID: 49	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-12		Collection Date: 10/14/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.015 AL	0.0051	mg/L	D	10/28/20 1253	10/30/20 1406	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-13		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0020	mg/L	D	10/28/20 1253	10/30/20 1409	LLW

Client Sample ID: 12	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-14		Collection Date: 10/14/2020 6:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0109	0.015 AL	0.0051	mg/L	D	10/28/20 1253	10/30/20 1417	LLW

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-15		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0020	mg/L	D	10/28/20 1253	10/30/20 1424	LLW

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-16		Collection Date: 10/14/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.015 AL	0.0051	mg/L	D	10/28/20 1253	10/30/20 1431	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-17		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.103	0.015 AL	0.0100	mg/L	D	10/29/20 1334	11/02/20 2150	LLW

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-18		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0020	mg/L	D	10/28/20 1253	10/30/20 1435	LLW

Client Sample ID: 17	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-19		Collection Date: 10/14/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1649	LLW

Client Sample ID: 14	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-20		Collection Date: 10/14/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1650	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-21		Collection Date: 10/14/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		10/28/20 1253	10/28/20 1652	LLW

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-22		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1702	LLW

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-23		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1707	LLW

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-24		Collection Date: 10/14/2020 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1709	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-25		Collection Date: 10/14/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1711	LLW

Client Sample ID: 13	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-26		Collection Date: 10/14/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1712	LLW

Client Sample ID: 16	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-27		Collection Date: 10/14/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1714	LLW

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-28		Collection Date: 10/14/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1720	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-29		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1722	LLW

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-30		Collection Date: 10/14/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1724	LLW

Client Sample ID: 56	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-31		Collection Date: 10/14/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1725	LLW

Client Sample ID: 31	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-32		Collection Date: 10/14/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1727	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-33		Collection Date: 10/14/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1731	LLW

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-34		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1733	LLW

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-35		Collection Date: 10/14/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1735	LLW

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-36		Collection Date: 10/14/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0159	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1736	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-37		Collection Date: 10/14/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0058	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1742	LLW

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-38		Collection Date: 10/14/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0075	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1744	LLW

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-39		Collection Date: 10/14/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1746	LLW

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-40		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1748	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-41		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/28/20 1255	10/28/20 1750	LLW

Client Sample ID: 26	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-42		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0090	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1801	LLW

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-43		Collection Date: 10/14/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1806	LLW

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-44		Collection Date: 10/14/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0062	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1808	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-45		Collection Date: 10/14/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0067	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1810	LLW

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-46		Collection Date: 10/14/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1812	LLW

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-47		Collection Date: 10/14/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1814	LLW

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-48		Collection Date: 10/14/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0070	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1819	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-49		Collection Date: 10/14/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		10/29/20 1334	10/30/20 1255	LLW

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-50		Collection Date: 10/14/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0082	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1821	LLW

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-51		Collection Date: 10/14/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0067	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1823	LLW

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1423-52		Collection Date: 10/14/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0187	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1825	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1423

Client Sample ID: 40	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:58
Lab Sample ID: J0J1423-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.015 AL	0.0010	mg/L		10/28/20 1442	10/28/20 1827	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 11/04/2020 19:05

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607)753-3403 Fax: (607)753-3415
 NY #10795, EPA #NY00935

Samples must be returned on ice
 MNY Workorder #

BALEW112

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Bocces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	
Sample Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data	
1	10/14/2020	10:03	DW	DW	1		
2		10:05					
3		10:05					
4		10:05					
5		10:00					
6		10:05					
7		10:05					
8		10:05					
9		10:05					
10		10:05					
11		10:10					
12		10:10					
13		10:15					
14		10:00					
15		10:15					
16		10:10					
17		10:15					
18		10:15					
19		10:20					
20		10:20					

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks



Print Name and Company
 Sampled: *[Signature]*
 Received: *Jennifer Walker*
 Received: *[Signature]*

Date/Time
 10/14/2020
 10/10/2020 700

Comments

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607)753-3403 Fax: (607)753-3415
 NY #10795, EPA #NY00935

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Bocces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in Mi)	
Fax Results:	Yes					Preservative	
Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Type				
57	10/14	6:30	DW	1			
29		6:45					
28		6:45					
23		6:47					
19		6:31					
13		6:20					
100		6:25					
30		6:57					
32		6:45					
15		6:25					
510		6:30					
31		6:57					
22		6:35					
24		6:45					
25		6:35					
18		6:32					
21		6:35					
34		6:48					
48		7:00					
27		6:50					

Date/Time
 10/14/2020

Print Name and Company

Sampled:
 Received:
 Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Belleville

Client Information		Billing/Invoice:		Analysis Requested				Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces							Ice:	YES NO
Address:	20104 NYS Route 3							Cooler:	YES NO
Contact:	Health/Safety Dept.							Sample Temp:	YES NO
Phone:	315-779-7000							Cooler Seal:	YES NO
Project:	Lead Testing	PO#:						Pickup:	YES NO
Quote ID:		Date Req.:						Dropoff:	C W
Rush TAT Bus. Days:	< 2-5 5-7 7-10							Accepted?	YES NO
Carbon Copy:	Yes							Container Material	
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com						Container Size (in Mi)	
Fax Results:	Yes							Preservative	
Sample Information			Matrix		Number of Containers for Analysis Requested				Comments/Field Data
Description/Location	Date	Time	Type						
3	10/14	645	DW	1					
26		645							
20		640							
46		706							
37		657							
39		655							
36		655							
47		700							
45		700							
35		657							
33		657							
38		653							
40		658							
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

Print Name and Company
 Date/Time
 Comments

Sampled:
 Received:
 Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.