



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Belle

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 06/28/2016 15:20
Reported: 07/28/2016 21:17

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6G0180-01
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0055, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1730

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6G0180-02
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1735

Analytical Testing Parameters

Client Sample ID: 34-1
Lab Sample ID: J6G0180-03
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1736



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 34-2
Lab Sample ID: J6G0180-04
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1738.

Analytical Testing Parameters

Client Sample ID: 32-1
Lab Sample ID: J6G0180-05
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1739.

Analytical Testing Parameters

Client Sample ID: 32-2
Lab Sample ID: J6G0180-06
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1741.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 31-1
Lab Sample ID: J6G0180-07
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1743

Analytical Testing Parameters

Client Sample ID: 31-2
Lab Sample ID: J6G0180-08
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1744

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6G0180-09
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0093, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1749



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6G0180-10
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1750

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6G0180-11
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1752

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6G0180-12
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1756



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 9-1
Lab Sample ID: J6G0180-13
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0054, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1758

Analytical Testing Parameters

Client Sample ID: 9-2
Lab Sample ID: J6G0180-14
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1759

Analytical Testing Parameters

Client Sample ID: 10-1
Lab Sample ID: J6G0180-15
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1801



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J6G0180-16
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1802

Analytical Testing Parameters

Client Sample ID: 29-1
Lab Sample ID: J6G0180-17
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1807

Analytical Testing Parameters

Client Sample ID: 29-2
Lab Sample ID: J6G0180-18
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1808



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 30-1
Lab Sample ID: J6G0180-19
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1810.

Analytical Testing Parameters

Client Sample ID: 30-2
Lab Sample ID: J6G0180-20
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1811.

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6G0180-21
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1813.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6G0180-22
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1814

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6G0180-23
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.16, 0.015, 0.0050, mg/L, GE, 07/21/16 1407, 07/22/16 1356

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6G0180-24
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1819



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J6G0180-25
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1821

Analytical Testing Parameters

Client Sample ID: 1-2
Lab Sample ID: J6G0180-26
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1825

Analytical Testing Parameters

Client Sample ID: 16-1
Lab Sample ID: J6G0180-27
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1827



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 16-2
Lab Sample ID: J6G0180-28
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1828

Analytical Testing Parameters

Client Sample ID: 27-1
Lab Sample ID: J6G0180-29
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1830

Analytical Testing Parameters

Client Sample ID: 27-2
Lab Sample ID: J6G0180-30
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1831



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6G0180-31
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1833

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6G0180-32
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1834

Analytical Testing Parameters

Client Sample ID: 22-1
Lab Sample ID: J6G0180-33
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1836



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 22-2
Lab Sample ID: J6G0180-34
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1843

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J6G0180-35
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1845

Analytical Testing Parameters

Client Sample ID: 2-2
Lab Sample ID: J6G0180-36
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1847



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 24-1
Lab Sample ID: J6G0180-37
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1848

Analytical Testing Parameters

Client Sample ID: 24-2
Lab Sample ID: J6G0180-38
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1850

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J6G0180-39
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1851



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J6G0180-40
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1853

Analytical Testing Parameters

Client Sample ID: 23-1
Lab Sample ID: J6G0180-41
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1854

Analytical Testing Parameters

Client Sample ID: 23-2
Lab Sample ID: J6G0180-42
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1856



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 13-1
Lab Sample ID: J6G0180-43
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1857

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J6G0180-44
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1902

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6G0180-45
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1906



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J6G0180-46
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1908

Analytical Testing Parameters

Client Sample ID: 15-1
Lab Sample ID: J6G0180-47
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1909

Analytical Testing Parameters

Client Sample ID: 15-2
Lab Sample ID: J6G0180-48
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1911



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: BG-1
Lab Sample ID: J6G0180-49
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1912.

Analytical Testing Parameters

Client Sample ID: BG-2
Lab Sample ID: J6G0180-50
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1914.

Analytical Testing Parameters

Client Sample ID: 33-1
Lab Sample ID: J6G0180-51
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1915.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 33-2
Lab Sample ID: J6G0180-52
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1920

Analytical Testing Parameters

Client Sample ID: 28-1
Lab Sample ID: J6G0180-53
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1922

Analytical Testing Parameters

Client Sample ID: 28-2
Lab Sample ID: J6G0180-54
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1923



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6G0180-55
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0051, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1925

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6G0180-56
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0067, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1929

Analytical Testing Parameters

Client Sample ID: 25-1
Lab Sample ID: J6G0180-57
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1931



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 25-2
Lab Sample ID: J6G0180-58
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1932.

Analytical Testing Parameters

Client Sample ID: 35-1
Lab Sample ID: J6G0180-59
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1934.

Analytical Testing Parameters

Client Sample ID: 35-2
Lab Sample ID: J6G0180-60
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1938.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6G0180-61
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0052, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1940

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6G0180-62
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1941

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J6G0180-63
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1943



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6G0180-64
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1945

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J6G0180-65
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.18, 0.015, 0.0050, mg/L, GE, 07/19/16 0954, 07/21/16 1946

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J6G0180-66
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0068, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1948



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6G0180-67
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1952

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6G0180-68
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1957

Analytical Testing Parameters

Client Sample ID: 26-1
Lab Sample ID: J6G0180-69
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 1958



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Analytical Testing Parameters

Client Sample ID: 26-2
Lab Sample ID: J6G0180-70
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 2000.

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J6G0180-71
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 2001.

Analytical Testing Parameters

Client Sample ID: 3-2
Lab Sample ID: J6G0180-72
Sample Type: Grab

Collected By: RF/FH
Collection Date: 06/28/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 0954, 07/21/16 2003.

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
E: Estimated result
MDL: Minimum Detection Limit
PQL: Practical Quantitation Limit
G: Result fails applicable NYS drinking water standards



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0180

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, Item, Yes. Rows include Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, and Received on Ice (or not required).

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Michael Fifield

Michael Fifield
Division Manager
07/28/2016 21:17

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.



J6G0180

Client Information		Billing/Invoices:		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	rfilley@booces.com					Container Size (in MI)	
Fax Results: Yes	ffhawck@booces.com					Preservative	

Sample Information			Number of Containers for Analysis Requested		Comments/Field D
Description/Location	Date	Time	Initial	Matrix Type	
1 20-1	6/28/10	7:37	RF		
2 20-2		7:40	RF		
3 34-1		7:21			
4 34-2		7:22			
5 32-1		7:17			
6 32-2		7:18			
7 31-1		7:14			
8 31-2		7:15			

Print Name and Company	Signature	Date/Time	Comments
Sampled: RAY FILEY FRED ANK	<i>[Signature]</i>	6/28/10	
Received: David Thomas	<i>[Signature]</i>	6/28/10 1520	
Received: Christine Rhodes M.V.	<i>[Signature]</i>	6/28/10 1520	
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY MNY Workorder

Bele

Client Information		Billing/Invoiced		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Leviss-Hamilton-Herkimer-Oneida BOCES						Ice: YES NO	
Address: 20104 NYS Route 3						Cooler: YES NO	
Contact: Watertown, NY 13601						Sample Temp: YES NO	
Phone: Ray Filley						Cooler Seal: YES NO	
Project: Lead Testing						Pickup: YES NO	
Quote ID: PO#:						Dropoff: C W	
Rush TAT Bus. Days: 2-5 5-7 7-10		Date Req:				Accepted? YES NO	
Relate to DOH: Yes						Container Material	
Email Results: Yes rfilley@boces.com		f.hawck@boces.com				Container size (in MI)	
Fax Results: Yes						Preservative	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			Comments/Field D
1 12-1	Ce/ces/ice	7:26	RF FH				
2 12-2		7:27					
3 21-1		7:36					
4 21-2		7:37					
5 9-1		7:03					
6 9-2		7:04					
7 10-1		7:00					
8 10-2		7:01					
Print Name and Company				Signature			
Sampled: Ray Filley Fred Hawck				Ray Filley Fred Hawck			
Received: David Thomas				Date/Time 6/28/16 15:20			
Received:				Received:			
Received:				Received:			
Received:				Received:			
Received:				Received:			
Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.							



J6G0180

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Beile



J6G0180

Client Information			Billing/Invoices			Analysis Requested			Receiving Info (Lab Use Only)					
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES	NO						
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES	NO						
Contact:	Ray Filley					Sample Temp:								
Phone:	315-779-7054					Cooler Seal:	YES	NO						
Project:	Lead Testing					Pickup:	YES	NO						
Quote ID:		PO#:				Dropoff:	C	W						
Rush TAT Bus. Days:	2-5	5-7	7-10	Date Req:		Accepted?	YES	NO						
Relate to DOH: Yes						Container Material								
Email Results: Yes	rfiley@boces.com		/f/hack@boce3.com			Container Size (in MI)								
Fax Results: Yes						Preservative								
Sample Information						Number of Containers for Analysis Requested			Comments/Field Data					
Description/Location	Date	Time	Initial	Matrix	Type									
29-1	6/28/16	7:18	RF											
29-2		7:19	PH											
30-1		7:16												
30-2		7:17												
17-1		7:34												
17-2		7:35												
5-1		7:10												
5-2		7:11												
Sampled: Ray Filley						Signature			Date/Time			Comments		
Received: David Thomas						Ray Filley			6/28/16 10:20					
Received:									6/29/16 15:20					
Received:														
Received:														
Received:														

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

J6G0180



Client Information		Billing/Invoices:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	YES NO
Phone:	Ray Filley					Cooler seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10					Accepted:	YES
Relate to DOH:	Yes					Container Material:	
Email Results:	Yes	filley@boces.com				Container Size (in MI):	
Fax Results:	Yes	filley@boces.com				Preservative:	
						Comments/Field D	

Sample Information			Number of Containers for Analysis Requested	
Description/Location	Date	Time	Initial	Matrix Type
1 1-1	6/28/16	7:25	RF	
2 1-2		7:00	FH	
3 1a-1		7:29		
4 1a-2		7:30		
5 27-1		7:43		
6 27-2		7:44		
7 6a-1		7:08		
8 6a-2		7:09		

Print Name and Company	Signature	Date/Time	Comments
Sampled: Ray Filley Flea Hawk	<i>Ray Filley</i>	6/28/16	
Received: David Romas	<i>David Romas</i>	6/29/16 15:20	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MNY Workorder #

Ball

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckiner, Oneida BOCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container size (in MI)	YES NO
Contact:	Watertown, NY 13601			Sample Temp:		Preservative	
Phone:	Ray Filley			Cooler Seal:	YES NO	Comments/Field Data	
Project:	Lead Testing			Pickup:	YES NO		
Quote ID:				Dropoff:	C W		
Rush TAT Bus. Days:	2 2-5 5-7 7-10			Accepted?	YES		
Release to DOH: Yes							
Email Results: Yes	filley@booces.com						
Fax Results: Yes	filley@booces.com						

Sample Information				Matrix		Number of Containers for Analysis Requested	
Description/Location	Date	Time	Initial	Type			
1 22-1	6/28/16	7:41	RF				
2 22-2		7:42	Fl				
3 2-1		7:03					
4 2-2		7:04					
5 24-1		7:44					
6 24-2		7:45					
7 14-1		7:27					
8 14-2		7:28					

Print Name and Company	Signature	Date/Time	Comments
Sampled: RAYMOND FILLEY	<i>[Signature]</i>	6/28/16	
Received: David Thomas	<i>[Signature]</i>	6/28/16 1520	
Received:			
Received:			
Received:			
Received:			

J6G0180

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00835

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

BEIIE

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH:	Yes					Container Material	
Email Results:	Yes	rfilley@boces.com				Container size (in MI)	
Fax Results:	Yes	rfilley@boces.com				Preservative	
		2008 Lead				Comments/Field Dc	
		P					
		250					
		HNO3					
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 23-1	6/28/12	7:31	RF				
2 23-2		7:40	PH				
3 13-1		7:29					
4 13-2		7:30					
5 4-1		7:08					
6 4-2		7:09					
7 15-1		7:32					
8 15-2		7:33					

Print Name and Company	Signature	Date/Time	Comments
Sampled: RAY FILLEY	<i>[Signature]</i>	6/28/12	
Received: David Thomas	<i>[Signature]</i>	6/24/16 1520	
Received:			
Received:			
Received:			
Received:			

J6G0180

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

MNY Workorder #

BE1E

Client Information		Billing/Invoice:		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10					Accepted?	YES
Relocate to DOH:	Yes					Container Material	
Email Results:	Yes	rfilley@boces.com				Container Size(in MI)	
Fax Results:	Yes	ffhack@boces.com				Preservative	
						Comments/Field D	

Sample Information			Number of Containers for Analysis Requested		Comments/Field D
Description/Location	Date	Time	Initial	Matrix Type	
1 BG1-1	6/28/02	7:57	RF		
2 BG1-2	6/28/02	7:58	FH		
3 33-1		7:22			
4 33-2		7:25			
5 28-1		7:45			
6 28-2		7:40			
7 7-1		7:10			
8 7-2		7:11			

Print Name and Company	Signature	Date/Time	Comment
Sampled: Ray Filley Fred Hack	<i>Ray Filley</i>	6/28/02	
Received: Paul J. Thomas	<i>Paul J. Thomas</i>	6/28/02 15:20	
Received:			
Received:			
Received:			
Received:			

J6G0180

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Belle

J6G0180

Client Information		Billing/Invoices		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush TAT Bur. Days:	<2 2-5 5-7 7-10	Date Req.:				Accepted?	YES
Relate to DOH:	Yes					Container Material	
Email Results:	Yes	rfilley@boces.com				Container Size (in MI)	
Fax Results:	Yes	rfilley@boces.com				Preservative	
						Comments/Field D	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 25-1	6/25/16	7:41	RF				
2 25-2		7:42	RF				
3 35-1		7:31					
4 35-2		7:32					
5 19-1		7:36					
6 19-2		7:37					
7 11-1		7:25					
8 11-2		7:26					
Print Name and Company				Signature		Date/Time	
Sampled: Ray Filley ProHorse				<i>Ray Filley</i>		6/28/16 1:00	
Received: David Ronda				<i>David Ronda</i>		6/28/16 15:20	
Received:							
Received:							
Received:							
Received:							
Comments							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MNY Workorder #

BELLE

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	Container Size (in MI)	YES NO
Contact:	Ray Filley			Sample Temp:	YES NO	Preservative	YES NO
Phone:	315-779-7054			Cooler Seal:	YES NO	Comments/Field D	
Project:	Lead Testing			Pickup:	YES NO		
Quote ID:				Dropoff:	C W		
Rush TAT Bus. Days:	<2 2-5 5-7 7-10			Accepted?	YES		
Release to DOH: Yes							
Email Results: Yes	rfilley@boces.com / <i>rfilley@boces.com</i>						
Fax Results: Yes							

Sample Information			Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Matrix Type	
1 8-1	6/28/10	7:12	RF		
2 8-2		7:13	FR		
3 18-1		7:34			
4 18-2		7:35			
5 26-1		7:48			
6 26-2		7:49			
7 3-1		7:05			
8 3-2		7:06			

Print Name and Company	Signature	Date/Time
Sampled: Kelly Filley Fees Hook	<i>Kelly Filley</i>	6/28/10 1:00
Received: David Thomas	<i>David Thomas</i>	6/23/10 15:20
Received:		
Received:		
Received:		
Received:		

J6G0180



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.