



February 23, 2024

Adam Passage
Jeff-Lewis BOCES Belleville Henderson Central
School District
8372 Country Rt. 75
Adams, NY 13605

RE: Project: PB
Pace Project No.: 70287571

Dear Adam Passage:

Enclosed are the analytical results for sample(s) received by the laboratory on February 16, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Chetram Budhu".

Chetram Budhu
chetram.budhu@pacelabs.com
516-886-5525
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: PB
Pace Project No.: 70287571

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 3		Lab ID: 70287571001		Collected: 02/14/24 05:40		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 12:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 4		Lab ID: 70287571002		Collected: 02/14/24 05:14		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 12:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 5		Lab ID: 70287571003		Collected: 02/14/24 05:33		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 13:00	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 6		Lab ID: 70287571004		Collected: 02/14/24 05:37		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 13:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 7		Lab ID: 70287571005		Collected: 02/14/24 05:18		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		02/21/24 13:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 8A ROOM 102 SINK		Lab ID: 70287571006		Collected: 02/14/24 04:22		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.0	ug/L	1.0	1		02/21/24 13:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 8B ROOM 102-DF		Lab ID: 70287571007		Collected: 02/14/24 04:23		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		02/21/24 13:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 9		Lab ID: 70287571008		Collected: 02/14/24 04:20		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.1	ug/L	1.0	1		02/21/24 13:10	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 10		Lab ID: 70287571009		Collected: 02/14/24 04:21		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		02/21/24 13:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 11		Lab ID: 70287571010		Collected: 02/14/24 04:27		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	5.8	ug/L	1.0	1		02/21/24 13:13	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 23		Lab ID: 70287571011		Collected: 02/14/24 04:37		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	12.6	ug/L	1.0	1		02/21/24 13:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 24		Lab ID: 70287571012		Collected: 02/14/24 04:38		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		02/21/24 13:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 25		Lab ID: 70287571013		Collected: 02/14/24 04:39		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.0	ug/L	1.0	1		02/21/24 13:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 26		Lab ID: 70287571014		Collected: 02/14/24 04:40		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		02/21/24 13:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 27		Lab ID: 70287571015		Collected: 02/14/24 04:44		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.3	ug/L	1.0	1		02/21/24 13:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 28		Lab ID: 70287571016		Collected: 02/14/24 04:45		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		02/21/24 13:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 29		Lab ID: 70287571017		Collected: 02/14/24 04:46		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	14.5	ug/L	1.0	1		02/21/24 13:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 30		Lab ID: 70287571018		Collected: 02/14/24 04:47		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 13:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 31		Lab ID: 70287571019		Collected: 02/14/24 04:48		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	19.5	ug/L	1.0	1		02/21/24 13:39	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 32		Lab ID: 70287571020		Collected: 02/14/24 04:49		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.2	ug/L	1.0	1		02/21/24 13:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 33		Lab ID: 70287571021		Collected: 02/14/24 04:53		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	10.1	ug/L	1.0	1		02/21/24 13:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 34		Lab ID: 70287571022		Collected: 02/14/24 04:54		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 13:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 35		Lab ID: 70287571023		Collected: 02/14/24 04:56		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	20.5	ug/L	1.0	1		02/21/24 13:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 36		Lab ID: 70287571024		Collected: 02/14/24 04:57		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		02/21/24 13:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 37		Lab ID: 70287571025		Collected: 02/14/24 04:58		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	17.8	ug/L	1.0	1		02/21/24 13:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 38		Lab ID: 70287571026		Collected: 02/14/24 04:59		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		02/21/24 13:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 39		Lab ID: 70287571027		Collected: 02/14/24 05:01		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	23.3	ug/L	1.0	1		02/21/24 13:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 40		Lab ID: 70287571028		Collected: 02/14/24 05:02		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		02/21/24 13:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 41		Lab ID: 70287571029		Collected: 02/14/24 05:03		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	23.5	ug/L	1.0	1		02/21/24 13:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 42		Lab ID: 70287571030		Collected: 02/14/24 05:04		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 14:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 43		Lab ID: 70287571031		Collected: 02/14/24 04:39		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	11.4	ug/L	1.0	1		02/21/24 14:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 45		Lab ID: 70287571032		Collected: 02/14/24 05:42		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		02/21/24 14:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 47		Lab ID: 70287571033		Collected: 02/14/24 05:52		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	9.0	ug/L	1.0	1		02/21/24 14:05	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 48		Lab ID: 70287571034		Collected: 02/14/24 05:47		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	14.2	ug/L	1.0	1		02/21/24 14:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 49		Lab ID: 70287571035		Collected: 02/14/24 05:32		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		02/21/24 14:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 51		Lab ID: 70287571036		Collected: 02/14/24 05:54		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		02/21/24 14:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 52		Lab ID: 70287571037		Collected: 02/14/24 05:55		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		02/21/24 14:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 53		Lab ID: 70287571038		Collected: 02/14/24 05:48		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.0	ug/L	1.0	1		02/21/24 14:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 54		Lab ID: 70287571039		Collected: 02/14/24 05:49		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		02/21/24 14:26	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: KITCHEN DISH WASHER		Lab ID: 70287571040		Collected: 02/14/24 05:06		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	53.3	ug/L	1.0	1		02/21/24 14:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: KITCHEN -HAND SINK		Lab ID: 70287571041		Collected: 02/14/24 05:07		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.9	ug/L	1.0	1		02/21/24 14:29	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: KITCHEN -3 BAY LEFT		Lab ID: 70287571042		Collected: 02/14/24 05:10		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.5	ug/L	1.0	1		02/21/24 14:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: KITCHEN -3 BAY RIGHT		Lab ID: 70287571043		Collected: 02/14/24 05:11		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		02/21/24 14:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: KITCHEN - 2 BAY		Lab ID: 70287571044	Collected: 02/14/24 05:12	Received: 02/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		02/21/24 14:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: DARK ROOM		Lab ID: 70287571045		Collected: 02/14/24 05:17		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.9	ug/L	1.0	1		02/21/24 14:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: ROOM 504-VISTERS LOCKER		Lab ID: 70287571046		Collected: 02/14/24 05:51		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.7	ug/L	1.0	1		02/21/24 14:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 12		Lab ID: 70287571047		Collected: 02/14/24 04:28		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		02/21/24 14:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 13		Lab ID: 70287571048		Collected: 02/14/24 04:24		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.2	ug/L	1.0	1		02/21/24 14:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 15		Lab ID: 70287571049		Collected: 02/14/24 04:25		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	8.8	ug/L	1.0	1		02/21/24 14:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 16		Lab ID: 70287571050		Collected: 02/14/24 04:26		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		02/21/24 14:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 17		Lab ID: 70287571051		Collected: 02/14/24 04:31		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	5.0	ug/L	1.0	1		02/21/24 14:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 18		Lab ID: 70287571052		Collected: 02/14/24 04:32		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		02/21/24 14:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 19		Lab ID: 70287571053		Collected: 02/14/24 04:33		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	6.3	ug/L	1.0	1		02/21/24 14:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 20		Lab ID: 70287571054		Collected: 02/14/24 04:34		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		02/21/24 14:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 21		Lab ID: 70287571055		Collected: 02/14/24 04:35		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	8.8	ug/L	1.0	1		02/21/24 15:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: PB
Pace Project No.: 70287571

Sample: BELL 22		Lab ID: 70287571056		Collected: 02/14/24 04:36		Received: 02/16/24 08:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/21/24 15:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS



QUALITY CONTROL DATA

Project: PB
Pace Project No.: 70287571

QC Batch:	338138	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70287571001, 70287571002, 70287571003, 70287571004, 70287571005, 70287571006, 70287571007, 70287571008, 70287571009, 70287571010, 70287571011, 70287571012, 70287571013, 70287571014		

METHOD BLANK: 1739006 Matrix: Water
Associated Lab Samples: 70287571001, 70287571002, 70287571003, 70287571004, 70287571005, 70287571006, 70287571007, 70287571008, 70287571009, 70287571010, 70287571011, 70287571012, 70287571013, 70287571014

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/21/24 12:36	

LABORATORY CONTROL SAMPLE: 1739007		Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Parameter	Units					
Lead	ug/L	50	51.5	103	85-115	

MATRIX SPIKE SAMPLE: 1739009		70287793005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Parameter	Units						
Lead	ug/L	<2.0	100	102	102	70-130	

MATRIX SPIKE SAMPLE: 1739011		70287793006 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Parameter	Units						
Lead	ug/L	<2.0	100	101	101	70-130	

SAMPLE DUPLICATE: 1739008		70287793005 Result	Dup Result	RPD	Qualifiers
Parameter	Units				
Lead	ug/L	<2.0	<2.0		

SAMPLE DUPLICATE: 1739010		70287793006 Result	Dup Result	RPD	Qualifiers
Parameter	Units				
Lead	ug/L	<2.0	<2.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: PB
Pace Project No.: 70287571

QC Batch:	338139	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70287571015, 70287571016, 70287571017, 70287571018, 70287571019, 70287571020, 70287571021, 70287571022, 70287571023, 70287571024, 70287571025, 70287571026, 70287571027, 70287571028, 70287571029, 70287571030, 70287571031, 70287571032, 70287571033, 70287571034		

METHOD BLANK:	1739012	Matrix:	Water
Associated Lab Samples:	70287571015, 70287571016, 70287571017, 70287571018, 70287571019, 70287571020, 70287571021, 70287571022, 70287571023, 70287571024, 70287571025, 70287571026, 70287571027, 70287571028, 70287571029, 70287571030, 70287571031, 70287571032, 70287571033, 70287571034		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/21/24 13:21	

LABORATORY CONTROL SAMPLE:	1739013					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.7	105	85-115	

MATRIX SPIKE SAMPLE:		1739015					
		70287571015	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	13.3	50	62.8	99	70-130	

MATRIX SPIKE SAMPLE:		1739017					
		70287571016	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.7	50	51.9	98	70-130	

SAMPLE DUPLICATE: 1739014

Parameter	Units	70287571015 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	13.3	13.4	0	

SAMPLE DUPLICATE: 1739016

Parameter	Units	70287571016 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.7	2.6	4	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: PB
Pace Project No.: 70287571

QC Batch:	338140	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70287571035, 70287571036, 70287571037, 70287571038, 70287571039, 70287571040, 70287571041, 70287571042, 70287571043, 70287571044, 70287571045, 70287571046, 70287571047, 70287571048, 70287571049, 70287571050, 70287571051, 70287571052, 70287571053		

METHOD BLANK:	1739018	Matrix:	Water
Associated Lab Samples:	70287571035, 70287571036, 70287571037, 70287571038, 70287571039, 70287571040, 70287571041, 70287571042, 70287571043, 70287571044, 70287571045, 70287571046, 70287571047, 70287571048, 70287571049, 70287571050, 70287571051, 70287571052, 70287571053		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/21/24 14:08	

LABORATORY CONTROL SAMPLE:	1739019					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.1	106	85-115	

MATRIX SPIKE SAMPLE:		1739021					
		70287571035	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.5	50	49.3	94	70-130	

MATRIX SPIKE SAMPLE:		1739023					
		70287571036	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	3.4	50	53.5	100	70-130	

SAMPLE DUPLICATE:	1739020				
Parameter	Units	70287571035 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.5	2.6	0	

SAMPLE DUPLICATE:	1739022				
Parameter	Units	70287571036 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.4	3.5	3	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: PB
Pace Project No.: 70287571

QC Batch: 338141 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70287571054, 70287571055, 70287571056

METHOD BLANK: 1739024 Matrix: Water
Associated Lab Samples: 70287571054, 70287571055, 70287571056

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/21/24 14:56	

LABORATORY CONTROL SAMPLE: 1739025

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.0	106	85-115	

MATRIX SPIKE SAMPLE: 1739027

Parameter	Units	70287571054 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.2	50	53.6	101	70-130	

MATRIX SPIKE SAMPLE: 1739029

Parameter	Units	70287571055 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.8	50	59.8	102	70-130	

SAMPLE DUPLICATE: 1739026

Parameter	Units	70287571054 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.2	3.2	2	

SAMPLE DUPLICATE: 1739028

Parameter	Units	70287571055 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	8.8	8.6	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: PB
Pace Project No.: 70287571

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PB
Pace Project No.: 70287571

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70287571001	BELL 3	EPA 200.8	338138		
70287571002	BELL 4	EPA 200.8	338138		
70287571003	BELL 5	EPA 200.8	338138		
70287571004	BELL 6	EPA 200.8	338138		
70287571005	BELL 7	EPA 200.8	338138		
70287571006	BELL 8A ROOM 102 SINK	EPA 200.8	338138		
70287571007	BELL 8B ROOM 102-DF	EPA 200.8	338138		
70287571008	BELL 9	EPA 200.8	338138		
70287571009	BELL 10	EPA 200.8	338138		
70287571010	BELL 11	EPA 200.8	338138		
70287571011	BELL 23	EPA 200.8	338138		
70287571012	BELL 24	EPA 200.8	338138		
70287571013	BELL 25	EPA 200.8	338138		
70287571014	BELL 26	EPA 200.8	338138		
70287571015	BELL 27	EPA 200.8	338139		
70287571016	BELL 28	EPA 200.8	338139		
70287571017	BELL 29	EPA 200.8	338139		
70287571018	BELL 30	EPA 200.8	338139		
70287571019	BELL 31	EPA 200.8	338139		
70287571020	BELL 32	EPA 200.8	338139		
70287571021	BELL 33	EPA 200.8	338139		
70287571022	BELL 34	EPA 200.8	338139		
70287571023	BELL 35	EPA 200.8	338139		
70287571024	BELL 36	EPA 200.8	338139		
70287571025	BELL 37	EPA 200.8	338139		
70287571026	BELL 38	EPA 200.8	338139		
70287571027	BELL 39	EPA 200.8	338139		
70287571028	BELL 40	EPA 200.8	338139		
70287571029	BELL 41	EPA 200.8	338139		
70287571030	BELL 42	EPA 200.8	338139		
70287571031	BELL 43	EPA 200.8	338139		
70287571032	BELL 45	EPA 200.8	338139		
70287571033	BELL 47	EPA 200.8	338139		
70287571034	BELL 48	EPA 200.8	338139		
70287571035	BELL 49	EPA 200.8	338140		
70287571036	BELL 51	EPA 200.8	338140		
70287571037	BELL 52	EPA 200.8	338140		
70287571038	BELL 53	EPA 200.8	338140		
70287571039	BELL 54	EPA 200.8	338140		
70287571040	KITCHEN DISH WASHER	EPA 200.8	338140		
70287571041	KITCHEN -HAND SINK	EPA 200.8	338140		
70287571042	KITCHEN -3 BAY LEFT	EPA 200.8	338140		
70287571043	KITCHEN -3 BAY RIGHT	EPA 200.8	338140		
70287571044	KITCHEN - 2 BAY	EPA 200.8	338140		
70287571045	DARK ROOM	EPA 200.8	338140		
70287571046	ROOM 504-VISTERS LOCKER	EPA 200.8	338140		
70287571047	BELL 12	EPA 200.8	338140		
70287571048	BELL 13	EPA 200.8	338140		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PB
Pace Project No.: 70287571

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70287571049	BELL 15	EPA 200.8	338140		
70287571050	BELL 16	EPA 200.8	338140		
70287571051	BELL 17	EPA 200.8	338140		
70287571052	BELL 18	EPA 200.8	338140		
70287571053	BELL 19	EPA 200.8	338140		
70287571054	BELL 20	EPA 200.8	338141		
70287571055	BELL 21	EPA 200.8	338141		
70287571056	BELL 22	EPA 200.8	338141		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Jeff-Lewis Boces, Belleville Henderson CSD
Street Address: 8372 County Rt. 75 Adams NY, 13605

Contact/Report To: Adam Passage
Phone #: 315-846-5411
E-Mail: Apassage@bhpanthers.org
Cc E-Mail:

Customer Project #: 08215392
Project Name: Belleville Henderson CSD

Invoice To: Adam Passage
Invoice E-Mail: Apassage@bhpanthers.org

Site Collection Info/Facility ID (as applicable):

Purchase Order # (if applicable):
Quote #:

Time Zone Collected: [] AK [] MT [] CT [X] ET
Data Deliverables:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW
Rush (Pre-approval required):
[] 12 Day [] 3 day [] 5 day [] Other
Date Results Requested: Standard 10 business day
Field Filtered (if applicable): [] Yes [] No
Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Waste Water (WW), Product (PI), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CLZ	Number & Type of Containers	
			Date	Time	Date	Time		Plastic	Glass
Beil 3	DW	G	2/14/24	0540				1	
4				0514					
5				0533					
6				0537					
7				0518					
8a Room 102-Sink				0722					
8b Room 102-DF				0723					
9				0720					
10				0721					
11				0727					

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By: Chris Pitzer
Printed Name: Chris Pitzer
Signature:

Relinquished by/Company: (Signature)
Date/Time: 2/15/24 12:20

Relinquished by/Company: (Signature)
Date/Time: 2/15/24 12:20

Relinquished by/Company: (Signature)
Date/Time: 2/15/24

Relinquished by/Company: (Signature)
Date/Time:

Additional Instructions from Pace*:

Coolers: ~~THU~~ Thermometer ID: ~~THU~~ Correction Factor (°C): ~~THU~~ Obs. Temp. (°C): 10.1 Corrected Temp. (°C): 10.5
Tracking Number: 6/15 12:20

Delivered by: [] In-Person [X] UPS [] Other

Page: 1 of 6

Company Name: Jeff-Lewis Boces, Belleville Henderson CSD
Street Address: 8372 County Rt. 75 Adams NY, 13605

Customer Project #: Belleville Henderson CSD
Project Name:

Site Collection Info/Facility ID (as applicable):

Contact/Report To: Adam Passage
Phone #: 315-846-5411
E-Mail: Apassage@bhpanthers.org
Cc E-Mail:

Invoice To: Adam Passage
Invoice E-Mail: Apassage@bhpanthers.org

Purchase Order # (if applicable):

Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):

[] 12 Day [] 3 day [] 5 day [] Other

Date Results Requested: Standard 10 business day

Field Filtered (if applicable): [] Yes [] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID

Matrix *

Comp / Grab

Collected (or Composite Start) Time

Date

Composite End Time

Res. CL2

Number & Type of Containers

Plastic

Glass

200.8 Drinking Water (Pb only)

X

Sample Comment

Proj. Mgr:

AccNum / Client ID:

Table #:

Profile / Template:

Prelog / Bottle Ord. ID:

Lab Use Only

Preservation non-conformance identified for sample:

**Container Size: (1) 1L (2) 500mL (3) 250mL (4) 125mL (5) 100mL (6) 40mL vial (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analysis Requested

Tracking Number:

Delivered by: [] In-Person [] Courier

[] FedEx [] UPS [] Other

Page: 2 of 6

ENV-FRM-CORQ-0019_v01_082123 ©

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Collected By: Chris Jurek

Printed Name:

Signature:

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Date/Time: 2/15 17:00

Additional Instructions from Pace®:

Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Date/Time: 2/15 12:20

Page 67

73

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

2/16 8:00

Company Name: Jeff-Lewis Boces, Belleville Henderson CSD
Street Address: 8372 County Rt. 75 Adams NY, 13605

Customer Project #: Belleville Henderson CSD

Site Collection Info/Facility ID (as applicable):

Contact/Report To: Adam Passage
Phone #: 315-846-5411
E-Mail: Apassage@bhpanthers.org
Cc E-Mail:

Invoice To: Adam Passage
Invoice E-Mail: Apassage@bhpanthers.org

Purchase Order # (if applicable):

Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[] 12 Day [] 3 day [] 15 day [] Other
Date Results Requested: Standard 10 business day

Field Filtered (if applicable): [] Yes [] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers	
		Date	Time	Date	Time		Plastic	Glass
DW	G	2/14/24	0437				1	
			0438					
			0439					
			0440					
			0444					
			0445					
			0446					
			0447					
			0448					
			0449					

Customer Remarks / Special Conditions / Possible Hazards:

Collected By: Chris Potter
Printed Name: Chris Potter
Signature: [Signature]

Relinquished by/Company: (Signature)

Relinquished by/Company: (Signature)

Relinquished by/Company: (Signature)

Relinquished by/Company: (Signature)

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time: 2/15 1700

Date/Time: 2/15/24

Date/Time: 2/15/24

Date/Time: 2/16 8:00

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Received by/Company: (Signature)

Date/Time: 2/15

Date/Time: 2/15

Date/Time: 2/15/24 22:15

Date/Time: 2/16 4:10

Tracking Number:

Delivered by: [] In-Person [X] Courier

[] FedEx [] UPS [] Other

Page: 3 of 6

LAB USE ONLY- Affix Workorder/Login Label Here

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Jeff-Lewis Boces, Belleville Henderson CSD
Street Address: 8372 County Rt. 75 Adams NY, 13605

Customer Project #: Belleville Henderson CSD

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET []

Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET []

Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required): [] 12 Day [] 15 day [] Other [] Yes [] No

Date Results Requested: Standard 10 business day

Analysis: Field Filtered (if applicable): [] Yes [] No

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (V), Other (OT)

Customer Sample ID

Matrix * Comp / Grab

Collected (or Composite Start) Date Time

Composite End Date Time

Res. CL2

Number & Type of Containers Plastic Glass

200.8 Drinking Water (Pb only)

Additional Instructions from Pace:

Collected By: Printed Name: Signature:

Received by/Company: (Signature) Date/Time:

Received by/Company: (Signature) Date/Time:

Received by/Company: (Signature) Date/Time:

Received by/Company: (Signature) Date/Time:

Tracking Number: Date/Time: 2/15 12:20

Delivered by: [] In-Person [] Courier [] FedEx [] UPS [] Other

Page: 6 of 6

ENV-FRM-CORO-0019_v01_082123 ©

Company Name: Jeff-Lewis Boces_Belleville Henderson CSD
Street Address: 8372 County Rt. 75 Adams NY, 13605

Contact/Report To: **Adam Passage**
 Phone #: **315-846-5411**
 E-Mail: Apassage@bhn.com
 Cc E-Mail:

Customer Project #: Belleville Henderson CSD
Project Name:

Invoice To:	Adam Passage
Invoice E-Mail:	Apassage@bhpanthers.org

Site Collection Info/Facility ID (as applicable):

Purchase Order # (if applicable):

Quote #:

County / State origin of sample(s):

in (DW, RCRA, etc.) as applicable; NY Lead in School DW

Rush (Pre-approval required):
☐ 2 Day ☐ 3 day ☐ 5 day ☐ Other _____

Date Results Requested: _____

Standard 10 business day

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [] Yes [] No

Analysis:

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End		Res. CL2	Number & Type of Containers	
			(or Composite Start)		Date	Time		Plastic	Glass
			Date	Time					
Bell 43	DW	G	2/14/24	0739				1	
45				0542					
47				0552					
48				0547					
49				0532					
51				0554					
52				0555					
53				0548					
54				0549					
Kitchen - Dishwasher				0506					

Customer Remarks / Special Conditions / Possible Hazards: Lead

Collected By: _____
Printed Name: _____
Signature: _____

Collected By: Chris
Printed Name: Chris
Signature: Chris

Collected By: Chris Potzer
Printed Name: Chris Potzer
Signature: Chris Potzer

Notwithstanding to/for company: (Signature)

Date/Time:

Relinquished by/Company: (Signature)

Date/Time:

Relinquished by/Company: (Signature)

Date/Time:

Relinquished by/Company: (Signature)

Date/Time:

INV-FRM-CORQ-0019_v01_082123 ©

Submitting a sample on this draft constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

LAB USE ONLY - Affix Workorder/Login Label Here

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Jeff-Lewis Boces, Belleville Henderson CSD
Street Address: 8372 County Rt. 75 Adams NY, 13605

Contact/Report To: Adam Passage
Phone #: 315-846-5411
E-Mail: Apassage@bhpanthers.org
Cc E-Mail:

Invoice To: Adam Passage
Invoice E-Mail: Apassage@bhpanthers.org

Purchase Order # (if applicable):
Quote #:

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [] AK [] MT [] CT [X] ET
Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[] 12 Day [] 3 day [] 15 day [] Other
Date Results Requested: Standard 10 business day

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID: k-risen - hand sink
- 3-bug test
- 3-bug fist
- 2-bug
Dark Room
Room 504-Vibrators Later

Matrix * DW
Comp / Grab G
Collected (or Composite Start) Date 2/14/24 Time 0507
Time 0510
0511
0512
0517
0551

Res. CL2
Number & Type of Containers Plastic Glass 1

Field Filtered (if applicable): [] Yes [] No
Analysis:

200.8 Drinking Water (Pb only) X

Preservation non-conformance identified for sample.

Proj. Mgr: Randy Budhu
AcctNum / Client ID:
Table #:
Profile / Template:
Prelog / Bottle Ord. ID:

Specify Container Size **
Identify Container Preservative Type***
Analysis Requested

** Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EriCore, (8) TerraCore, (9) Other
*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Additional Instructions from Pace*:
Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)
1 TH211 +0.4 10.1 10.5
Tracking Number:
Date/Time: 2/15 12:20
Date/Time:
Delivered by: [] In-Person [X] Courier
[] FedEx [] UPS [] Other
Page: 6 of 6

Customer Remarks / Special Conditions / Possible Hazards:
Lead
Collected By: Chris Porter
Printed Name: Chris Porter
Signature: [Signature]
Received by/Company: Signature: [Signature]
Date/Time: 2/15 1700
Date/Time: 2/15/24
Date/Time: 2/15/24
Date/Time: 2/16 4:10

Relinquished by/Company: Signature: [Signature]
Relinquished by/Company: Signature: [Signature]
Relinquished by/Company: Signature: [Signature]
Relinquished by/Company: Signature: [Signature]

Submitting a sample with this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Page 71 of 73

3/16 8:00

2/16 2:10pm 8:00

Client: Bellevilles
Ward: 40

Profile #: 10553

☐ Use Point Number Spreadsheet

☐ Multiday Project

☐ Add SCLOGPD to first sample for field charge

COC Page _____ of _____

COC	Sample	Matrix	Container	Material	Volume	Weight	Notes	Analysis	Results	Comments
1	1	1	1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2	2	2	2
3	3	3	3	3	3	3	3	3	3	3
4	4	4	4	4	4	4	4	4	4	4
5	5	5	5	5	5	5	5	5	5	5
6	6	6	6	6	6	6	6	6	6	6
7	7	7	7	7	7	7	7	7	7	7
8	8	8	8	8	8	8	8	8	8	8
9	9	9	9	9	9	9	9	9	9	9
10	10	10	10	10	10	10	10	10	10	10
11	11	11	11	11	11	11	11	11	11	11
12	12	12	12	12	12	12	12	12	12	12
13	13	13	13	13	13	13	13	13	13	13
14	14	14	14	14	14	14	14	14	14	14
15	15	15	15	15	15	15	15	15	15	15
16	16	16	16	16	16	16	16	16	16	16
17	17	17	17	17	17	17	17	17	17	17
18	18	18	18	18	18	18	18	18	18	18
19	19	19	19	19	19	19	19	19	19	19
20	20	20	20	20	20	20	20	20	20	20
21	21	21	21	21	21	21	21	21	21	21
22	22	22	22	22	22	22	22	22	22	22
23	23	23	23	23	23	23	23	23	23	23
24	24	24	24	24	24	24	24	24	24	24
25	25	25	25	25	25	25	25	25	25	25
26	26	26	26	26	26	26	26	26	26	26
27	27	27	27	27	27	27	27	27	27	27
28	28	28	28	28	28	28	28	28	28	28
29	29	29	29	29	29	29	29	29	29	29
30	30	30	30	30	30	30	30	30	30	30
31	31	31	31	31	31	31	31	31	31	31
32	32	32	32	32	32	32	32	32	32	32
33	33	33	33	33	33	33	33	33	33	33
34	34	34	34	34	34	34	34	34	34	34
35	35	35	35	35	35	35	35	35	35	35
36	36	36	36	36	36	36	36	36	36	36
37	37	37	37	37	37	37	37	37	37	37
38	38	38	38	38	38	38	38	38	38	38
39	39	39	39	39	39	39	39	39	39	39
40	40	40	40	40	40	40	40	40	40	40
41	41	41	41	41	41	41	41	41	41	41
42	42	42	42	42	42	42	42	42	42	42
43	43	43	43	43	43	43	43	43	43	43
44	44	44	44	44	44	44	44	44	44	44
45	45	45	45	45	45	45	45	45	45	45
46	46	46	46	46	46	46	46	46	46	46
47	47	47	47	47	47	47	47	47	47	47
48	48	48	48	48	48	48	48	48	48	48
49	49	49	49	49	49	49	49	49	49	49
50	50	50	50	50	50	50	50	50	50	50
51	51	51	51	51	51	51	51	51	51	51
52	52	52	52	52	52	52	52	52	52	52
53	53	53	53	53	53	53	53	53	53	53
54	54	54	54	54	54	54	54	54	54	54
55	55	55	55	55	55	55	55	55	55	55
56	56	56	56	56	56	56	56	56	56	56
57	57	57	57	57	57	57	57	57	57	57
58	58	58	58	58	58	58	58	58	58	58
59	59	59	59	59	59	59	59	59	59	59
60	60	60	60	60	60	60	60	60	60	60
61	61	61	61	61	61	61	61	61	61	61
62	62	62	62	62	62	62	62	62	62	62
63	63	63	63	63	63	63	63	63	63	63
64	64	64	64	64	64	64	64	64	64	64
65	65	65	65	65	65	65	65	65	65	65
66	66	66	66	66	66	66	66	66	66	66
67	67	67	67	67	67	67	67	67	67	67
68	68	68	68	68	68	68	68	68	68	68
69	69	69	69	69	69	69	69	69	69	69
70	70	70	70	70	70	70	70	70	70	70
71	71	71	71	71	71	71	71	71	71	71
72	72	72	72	72	72	72	72	72	72	72
73	73	73	73	73	73	73	73	73	73	73
74	74	74	74	74	74	74	74	74	74	74
75	75	75	75	75	75	75	75	75	75	75
76	76	76	76	76	76	76	76	76	76	76
77	77	77	77	77	77	77	77	77	77	77
78	78	78	78	78	78	78	78	78	78	78
79	79	79	79	79	79	79	79	79	79	79
80	80	80	80	80	80	80	80	80	80	80
81	81	81	81	81	81	81	81	81	81	81
82	82	82	82	82	82	82	82	82	82	82
83	83	83	83	83	83	83	83	83	83	83
84	84	84	84	84	84	84	84	84	84	84
85	85	85	85	85	85	85	85	85	85	85
86	86	86	86	86	86	86	86	86	86	86
87	87	87	87	87	87	87	87	87	87	87
88	88	88	88	88	88	88	88	88	88	88
89	89	89	89	89	89	89	89	89	89	89
90	90	90	90	90	90	90	90	90	90	90
91	91	91	91	91	91	91	91	91	91	91
92	92	92	92	92	92	92	92	92	92	92
93	93	93	93	93	93	93	93	93	93	93
94	94	94	94	94	94	94	94	94	94	94
95	95	95	95	95	95	95	95	95	95	95
96	96	96	96	96	96	96	96	96	96	96
97	97	97	97	97	97	97	97	97	97	97
98	98	98	98	98	98	98	98	98	98	98
99	99	99	99	99	99	99	99	99	99	99
100	100	100	100	100	100	100	100	100	100	100

Container Count

WT	Water
SL	Solid
NAL	Non-aqueous Liquid
OL	Oil
WP	Wipe
DW	Drinking Water

IOC	IOC
BP1U	1L unpreserved plastic
BP3M	250mL HNO3 plastic
BP3C	250mL Sodium Hydroxide
AG2U	500mL unpres amber glass

* Can also be a BP4N

SOC	SOC
VG5T	40mL Na Thio amber vial
DG9A	40mL Ascorbic acid making Acid vial
DG9Y	Citrate/Na Thiosulfate 40mL
DG6T	Na Thiosulfate 60mL vial
DG6M	MonoGlactate/Na Thio 60mL
AG3U	250mL unpres amber glass
AG3T	Na Thiosulfate 250mL bottle
BP1B	Na Thiosulfate Amber bottle
AG1T	Na Thiosulfate 1L Amber
AG1A	525.3 Chemical Blend

Sender Initials _____

Additional Comments _____

WO#: 70287571
PM: CB1
Due Date: 02/26/24
CLIENT: Bellevilles

WO#: 70287571

Client Name: BellevilleCS

Project # PM: CB1 Due Date: 02/26/24
CLIENT: BellevilleCS

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #: _____

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No
Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziplo ☐ Non ☒ Other Type of Ice: Wet Blue None

Thermometer Used: TH211 Correction Factor: r 0.11 ☒ Samples on ice, cooling process has begun
Cooler Temperature(°C): 10.1 Cooler Temperature Corrected(°C): 10.5 Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 5.0°C

USDA Regulated Soil ☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX,
or VA (check map)? ☐ Yes ☒ No

Did samples originate from a foreign source including Hawaii and Puerto Rico? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: ASF 2/16/24

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container,
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12. <u>30 kitchen dish washer time on coc</u>
-Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER		<u>is 5:06 but on bottle is 5:05 and for hand</u>

Date and Initials of person checking preservation: see below

All containers needing preservation have been	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>713623V</u>		Sample #
All containers needing preservation are found to be in compliance with method recommendation?		
(HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A		
NAOH > 12 Cyanide)		
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		
Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed:	Lot # of added preservative:
KI starch test strips Lot #		Date/Time preservative added:
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine?	Y N
Lead Acetate Strips Lot #	15. Positive for Sulfide?	Y N
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A		

DATE AND INITIALS OF PERSON COMPLETING SECOND REVIEW: pp 2/16/24

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: On bottles 2 were label Bell 28 but one is suppose to be Bell 24 so put labels based on time, bottles were label Bell 35 while one supposed to Bell 37 so label based on time, and 2 bottles were label Bell 36 and one is supposed to be bell 38 so did the same thing again

* PM (Project Manager) review is documented electronically in LIMS.